

APPENDIX 2- NOTIFICATION TEMPLATE
IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
Este informe contiene informaci6n muy importante sobre su agua potable.
Por favor hable con alguien que lo pueda traducir.

**Gratton School Has levels of 1,2,3-TCP
Above Drinking Water Standards**

Our water system recently failed a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what you should do, what happened, and what we are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Testing results we received on February 4, 2021 show that our system exceeds the standard, or maximum contaminant level(MCL), for 1,2,3-trichloropropane (1,2,3-TCP). The standard for 1,2,3-TCP is 0.005 ug/L (micrograms per liter) equivalent to 0.000005 mg/L (milligrams per liter). The average level of 1,2,3-TCP over the 1st Quarter 2021 was 0.008 ug/L OR 0.000008 mg/L. The RAA as of 1Q2021 is 0.008 ug/L OR 0.000008 mg/L.

What should I do?

- **You do not need to use an alternative (e.g., bottled) water supply.**
- This is not an immediate risk. If it had been, you would have been notified immediately. However, some *people who drink water containing 1,2,3-trichloropropane in excess of the MCL over many years may have an increased risk of getting cancer.*
- If you have other health issues concerning the consumption of this water, you may wish to consult your doctor.

What happened? What was done?

Source of 1,2,3-TCP contamination is unknown, investigation is underway. Possible corrective measures are being explored alongside the local environmental health authorities. The State Water Control Board is working on obtaining funding for a permanent mitigation option and we await further updates on the matter.

We anticipate resolving the problem within the foreseeable future.

For more information, please contact:

[Name of Contact] Quality Service, Inc at (209) 838-7842

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(9)]:

- **SCHOOLS:** Must notify school employees, students, and parents (if the students are minors).
- **RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS** (including nursing homes and care facilities): Must notify tenants.
- **BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS:** Must notify employees of businesses located on the property.

This notice is being sent to you by Gratton School in compliance with the California Domestic Water Quality and Monitoring Regulations as a means of keeping the public informed.

APPENDIX 3 - CERTIFICATION OF COMPLETION OF PUBLIC NOTIFICATION

Compliance Order Number: DER-19R-014

Name of Water System: Gratton School

System Number: 5000273

Attach a copy of the public notice distributed to the water system's customers.

This form, when completed and sent to Environmental Health, serves as certification that public notification to water users was completed as required by California Code of Regulations, Title 22, Sections 64463-64465.

Public notification for failure to comply with the **.1,2,3-TCP MCL** was conducted on:

Notification was made on March 30, 2021 (date).

For the following monitoring period: 1st 2nd 3rd 4th quarter(s) of 2021 (year).
(Circle appropriate quarter(s))

To summarize report delivery used and good-faith efforts taken, please check all items below that apply and fill-in where appropriate:

For Community and non-transient non-community public water systems

The notice was distributed by mail or direct delivery to each customer on: _____

One or more of the following methods were used to reach persons not likely to be reached by a mailing or direct delivery or persons served by a transient public water system (renters, nursing home patients, prison inmates, etc.):

Posted the notice at the following conspicuous locations served by the water system. (If needed, please attach a list of locations). posting on a public bulletin board on campus
Publication of the notice in a local newspaper or newsletter of general circulation (attach a copy of the published notice, including name of newspaper and date published).

Posted the notice on the Internet at www.grattonschool.net
Other method used to notify customers. _____

I hereby certify that the above information is factual.

Certified by: Printed Name Wendy Williams Title Superintendent

Signature [Handwritten Signature]

Date March 30, 2021

Disclosure: Be advised that the California Health and Safety Code, Sections 116725 and 116730 state that any person who knowingly makes any false statement on any report or document submitted for the purpose of compliance with the Safe Drinking Water Act may be liable for, respectively, a civil penalty not to exceed five thousand dollars (\$5,000) for each separate violation or, for continuing violations, for each day that violation continues, or be punished by a fine of not more than \$25,000 for each day of violation, or by imprisonment in the county jail not to exceed one year, or by both the fine and imprisonment.

APPENDIX 4 - QUARTERLY PROGRESS REPORT

Water System: Gratton School	Water System No: 5000273
Compliance Order No: DER-19R-014	Violation: 1,2,3-TCP MCL
Calendar Quarter: 1 st Quarter 2021	Date: March 30, 2021

This form should be prepared and signed by Gratton School personnel with appropriate authority to implement the directives of the Compliance Order and the Corrective Action Plan. Please attach additional sheets as necessary. The quarterly progress report must be submitted by the 10th day of each subsequent quarter, to the Environmental Health to the following email address: LPAStanislaus@envres.org titled appropriately.

Summary of Compliance Plan:

The System will Investigate groundwater and treatment options and then determine the most feasible option to address the water quality concern. After which, the project will be designed and implemented by June 24, 2022.

Tasks completed in the reporting quarter:

Gratton School District continued working with Self-Help enterprises to provide information needed to complete the grant application for the state to resolve TCP contamination.

Tasks remaining to complete:

Wait for grant application process to be finalized to move towards project completion.

Anticipated compliance date:

June 24, 2022

Wendy Williams

Printed Name

[Handwritten Signature]

Signature

Superintendent

Title

March 30, 2021

Date